

N00204.AR.004777
NAS PENSACOLA
5090.3a

TRANSMITTAL LETTER WITH COMMENTS REGARDING DECEMBER 1995 MONTHLY
OPERATION AND MAINTENANCE REPORT ON THE DOMESTIC WASTEWATER
TREATMENT PLANT GROUNDWATER REMEDIATION NAS PENSACOLA FL
12/28/1995
RUST ENVIRONMENTAL & INFRASTRUCTURE INC

RUST Rust Environment & Infrastructure Inc.

A Rust International Company Phone 803.572.5600
2694 Lake Park Drive Fax 803.572.5661
North Charleston, SC 29406

December 28, 1995

Commanding Officer
Naval Public Works Center, Code 480
Attn: Mr. Tom Kelley
Naval Air Station
Pensacola, FL 32508-6500

Re: December 1995 Monthly Operation and Maintenance
Report on the Industrial Wastewater Treatment Plant (IWTP)
Ground-Water Remediation
Naval Air Station (NAS) Pensacola, Florida
Contract No. N62467-93-D-0662, Delivery Order No. 0045
Rust Project No. 33561.000

Dear Sir:

Rust Environment and Infrastructure (Rust) is pleased to submit a monthly operation and maintenance report on the IWTP ground-water remediation for the above referenced project. Two (2) copies of the report have been sent to Mr. Tom Sailors with Southern Division, Naval Facilities Engineering Command and two (2) copies to Commander, Naval Air Station, Environmental Division, Attention: Mr. Bill Taylor. Rust has the following comments for the month of December 1995.

RECOVERY WELL SYSTEM OPERATION STATUS

RW 1,2 & 3; RW 4 & 6; RW 5A; RW7

1. The recovery well system remained "off-line" during the month of December 1995, as directed.
2. Rust representative is awaiting instructions as to the operation and maintenance requirements of the new pretreatment air stripper unit.
3. The November 1995 monthly operation and maintenance report stated that recovery well No. 7 is not presently tied into the new pretreatment air stripper unit electrically. On November 21, 1995 RW 7 was operating properly upon arrival to perform the O&M service and the flowmeter reflected a pumping rate of 2.5 GPM. Rust representative observed that the flowmeter at the new pretreatment air


Mr. Tom Kelley
December 28, 1995
Rust Project No. 33561.000
Page Two

stripper unit reflected zero flow. The possibility exists that RW 7 may not be piped into the air stripper unit at the present time or that the new flowmeter was not functioning.

4. Recovery well water levels were not obtained during the month of December 1995.

As always, if there are any questions regarding this report or other matters pertaining to this project, please feel free to contact me or Susan Burdick at (803) 572-5600.

Sincerely,



Tommy E. Moody
Project O&M

Enclosure

- c: Tom Sailors - NAVFAC - Code 1826 (2 copies)
Bill Taylor - NAS, Environmental Division (2 copies)
Brian Caldwell - ENSAFE
Susan Burdick - Rust