

New York State Department of Environmental Conservation
Building 40—SUNY, Stony Brook, New York 11790-2356
(516) 751-7725 or 7900
Fax #516-751-3839



Thomas C. Jerling
Commissioner

June 4, 1992

Mr. John Ohlmann, P.E.
Grumman Corporation
Mail Stop D08-GHQ
Bethpage, NY 11714-3580

Re: Grumman, Calverton: Oil Spill #'s
82-0923, Fuel Depot
82-1680, Fire Training Area
84-0011, Fuel Calibration Area

Dear Mr. Ohlmann:

This letter summarizes our meeting of May 29, 1992 regarding the above referenced spill sites. The following items were discussed at the meeting:

1. The existing discharges from the fire training area and the fuel calibration area must be sampled three times for volatiles, semi-volatiles, metals, inorganics, PCB's and pesticides. The purpose of conducting this sampling will be to determine the necessary treatment to bring these two remediations into full compliance.
2. Subsequent to the sampling events, the discharges for the fire training area and fuel calibration area must be discontinued until such time that the appropriate treatment is in place and the necessary permits have been granted.
3. Monitoring of fire training area, fuel calibration area and fuel depot will continue at the same frequency.

As we discussed at our meeting, we would like to stress the importance of aggressively pursuing remedial activities at all three spill sites. Delaying cleanup of these three areas until additional studies are completed will only result in further plume migration.

J. OHLMANN

JUN 8 1992

Page 2

Upon receipt of the water quality data from the two discharges, please contact this office to arrange further discussion regarding future remedial activities.

Sincerely,



J. Douglas Picha, P.E.
Regional Spill Engineer

JDP:ic

cc: R. Cowen, Regional Director
R. Becherer
J. Hofmann
W. Parish
- D. Felton, NAVFAC
M. Simonson, DPRO - Bethpage
D. Brayack, Halliburton NUS