

N00164.AR.002439
NSA CRANE
5090.3a

LETTER REGARDING INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
CONCERNS WITH ENVIRONMENTAL INVESTIGATION REPORT BUILDING 181 AREA NSA
CRANE IN
3/13/2013
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

Hickey, Howard M CIV NAVFAC MW EV

From: GRIFFIN, DOUG [DGRIFIN@idem.IN.gov]
Sent: Wednesday, March 13, 2013 9:20 AM
To: Brent, Thomas CIV NAVFAC MW, PWD Crane EV
Subject: Bldg 181 Area EI Report

Tom, no concerns about the investigation or the conclusions.

The two sumps are probably a safety hazard and should probably be removed, but that's your decision.

I've discussed the tank with the UST Section Chief. The dates of use put it within the time a UST might have been required to be registered, but in view of the fact that the water sample in the tank was basically clean he says you can consider it a process tank and just pull it without any UST Program oversight.