

N60478.AR.001422
NWS EARLE
5090.3a

TRANSMITTAL LETTER FOR THE STATE OF NEW JERSEY DEPARTMENT OF
ENVIRONMENTAL PROTECTION COMMENTS ON UNDERGROUND STORAGE TANK
WORK PLAN FOR VARIOUS SITES NWS EARLE NJ

5/18/1994

STATE OF NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL
PROTECTION AND ENERGY

THE TODD WHITMAN
Governor

ROBERT C. SHINN, JR.
Commissioner

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
NO: P 839 136 802

MAY 18 1994

John Pawlus
Naval Weapons Station - Earle
Code 096, Building C29
Route 34
Colts Neck, NJ 07722-5000

Re: UST RI Workplan for Various Sites
NWS Earle
Colts Neck Township, Monmouth County

Dear Mr. Pawlus:

The New Jersey Department of Environmental Protection and Energy (NJDEPE) has reviewed the above referenced Work Plan submitted by Halliburton NUS Corp., dated June 1993. The NJDEPE approves the work plan provided the following comments are incorporated.

- 1) The Geoprobe method of soil sampling is acceptable, however equipment and procedures used in the Geoprobe method must be discussed in further detail. Soil sample collection shall be in accordance with the 5/1992 NJDEPE Field Sampling Procedures Manual.
- 2) A more detailed description of the ground water monitoring program shall be included, for example how will ground water samples be collected, i.e., pump or bailer.
- 3) According to the diagrams in the workplan, some of the soil borings are located as far as sixty (60) feet away from the former tank excavation(s). The borings shall be within ten (10) to fifteen (15) feet of the former excavation.

If you have any questions regarding the aforementioned comments, please contact me at (609)-633-1455.

Sincerely,

Bob Marcolina, Case Manager
Bureau of Federal Case Management