

N60478.AR.001433
NWS EARLE
5090.3a

TRANSMITTAL LETTER FOR THE STATE OF NEW JERSEY DEPARTMENT OF
ENVIRONMENTAL PROTECTION COMMENTS ON UNDERGROUND STORAGE TANK
REMEDIAL INVESTIGATION WORK PLAN FOR GROUP 2 SITES NWS EARLE NJ
11/22/1994
STATE OF NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION



State of New Jersey

Christine Todd Whitman
Governor

Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

NOV 22 1994

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
NO: P 839 137 284

John Pawlus
Naval Weapons Station - Earle
Code 096, Building C29
Route 34
Colts Neck, NJ 07722-5000

Re: UST Remedial Investigation Workplan for Various Sites
Group II
NWS Earle
Colts Neck Township, Monmouth County

Dear Mr. Pawlus:

The New Jersey Department of Environmental Protection (NJDEP) has reviewed and approved the above referenced document pending incorporation of the following comments:

- 1) Page 2-52 - The TPH analyses for ground water cannot be used as a screening tool as it is for soils. The ground water analysis requirements for fuel oil contamination are B/Ns+15 and VO_s+ 10. See further details in Section 2.1 of 7:26E (Technical Requirements for Site Remediation).
- 2) Figure 2-23 - Please include the location for UST # C8/1.
- 3) Section 2.21.1 - Confirmatory soil sampling is required for C8/2. The Department cannot accept a "no further action" recommendation based only on the results of a tank tightness test.
- 4) Pursuant to our discussions, the approximate review time for this particular document is 16 hours, which translates into an oversight cost of \$865.92. Attached is the explanation of the oversight cost accounting. Be advised that the oversight cost bill that you will receive will not itemize each UST document review, it will be the total costs for all UST document reviews to date.

If you have any questions, please contact me at (609)-633-1455.

Sincerely,

Bob Marcolina, Case Manager
Bureau of Federal Case Management