

N00210.AR.001244
NSTC GREAT LAKES, IL
5090.3a

TRANSMITTAL LETTER REGARDING 45 DAY REPORT FOR THE LEAKING
UNDERGROUND STORAGE TANK BUILDING 229 NS GREAT LAKES IL
5/19/1999
DEPARTMENT OF THE NAVY



365

DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER
AND
ENGINEERING FIELD ACTIVITY, MIDWEST
BUILDING 1-A
2703 SHERIDAN ROAD, SUITE #120
GREAT LAKES, ILLINOIS 60088-5600

5090
Ser N45/ 000244

19 MAY 1999

Illinois Environmental Protection Agency
Bureau of Land #24
Leaking Underground Storage Tank Section
1021 North Grand Avenue East
Springfield, Illinois 62702

Subj: NAVAL TRAINING CENTER (NTC) – GREAT LAKES
BUILDING 229, IEMA INCIDENT #990458
IEPA GENERATOR #0971255004

Ladies and Gentlemen:

Attached is the 45 Day Report for the Leaking Underground Storage (LUST) Program for the subject site/building.

Contaminated soils were encountered during removal of three (3) underground storage tanks at Building 229 on February 26, 1999. The piping systems connected to the tanks and the tanks themselves were found to be in poor condition. As a result, the surrounding soil was contaminated with #2 diesel fuel and waste oils.

The point of contact is Mr. JP Messier at (847) 688-5999 extension 51.

Sincerely,

MARK SCHULTZ
Director, Environmental Department
By direction of
the Commanding Officer

Enclosure: 1. 45 Day Report