

N00639.AR.002058
NSA MID SOUTH
5090.3a

LETTER DISCUSSING APPROVED CONSTRUCTION PERMIT FOR EMERGENCY
MONITORING WELLS AT SOLID WASTE MANAGEMENT UNITS 59 AND 65 MILLINGTON
SUPPACT TN
11/6/1995
MEMPHIS AND SHELBY COUNTY HEALTH DEPARTMENT



MEMPHIS AND SHELBY COUNTY
HEALTH DEPARTMENT

YVONNE S. MADLOCK
Director

JOHN B. KIRKLEY, M.D.
Interim Health Officer



DR. W. W. HERENTON
Mayor of Memphis

JIM ROUT
Mayor of Shelby County

November 6, 1995

Mr. Ben Brantley
The InSitu Group/Ensafe Allen & Hoshall
5724 Summer Trees Drive
Memphis, TN 38134


RE: EMERGENCY CONSTRUCTION OF A MONITORING WELL(S):
Naval Support Activity
South Complex, Bldg. S-335, Former Pesticide Shop SWMU 59
South Complex, Bldg. S-362, Training Mock-Up SWMU 65
Permit #95-206

Dear Mr. Brantley:

This letter acknowledges the oral approval given by this Office for emergency construction of a well at the above referenced location. The **"CONSTRUCTION PERMIT"** documenting the procedure is enclosed. You are expected to comply with all conditions indicated on the permit as well as the specifications outlined on the application. The permit must be maintained at the job site for the duration of the construction process.

Your prompt attention and cooperation in this matter will be appreciated. In the meantime if you have any questions, please contact Mr. Greg Parker at (901) 576-7741.

Sincerely,


J. Carter S. Gray, Manager
POLLUTION CONTROL SECTION

BFD/GP:JCSG:mpc

Enclosure

WATER QUALITY CONTROL

MEMPHIS AND SHELBY COUNTY HEALTH DEPARTMENT


MONITORING WELL CONSTRUCTION PERMIT

WELL DRILLING COMPANY INSITU GROUP/ENSAFE/ALLEN AND HOSHALL
ADDRESS 5724 Summer Trees Drive Memphis, TN 38134
DATE ISSUED 10/11/95 EXPIRATION DATE 1/11/96 PERMIT # 95-206
DESCRIPTION OF WORK Construction of Monitoring Wells at: Naval Support Activity
EMERGENCY PERMIT South Complex, Bldg. S-335, SWMU 59 and Bldg. S-362, SWMU 65

This permit is issued based on signed commitment by the driller and the owner of said well to fully comply with the requirements set forth in the approved application or as directed by the Memphis and Shelby County Health Department. Deviation from the approved application or any conditions that are set forth by the Health Department shall void this permit.

CONDITIONS:

1. Any water used in drilling these wells shall be obtained from a potable source and a chlorine residual maintained throughout the drilling process.
2. All applicable fees must be paid to the Memphis and Shelby County Health Department.
3. The Health Department shall be notified 24 hours before construction of well or wells is to begin.
4. A copy of the well logs shall be submitted to the Health Department within (30) thirty days of completion.
5. A copy of sample results must be submitted to this office within (60) sixty days of completion of the well.
6. All requirements outlined in the Rules and Regulations shall be complied with.
7. Any changes in the number of wells needed, or in their location of construction such as conversion to a recovery well shall be brought to the attention of the Health Department.
8. Any additional wells that may be needed at a later date will require a separate application be filed with this office along with the \$25.00 (twenty-five dollar) processing fee and the \$100.00 (one hundred dollar) inspection fee.
9. Siting requirements for water wells will be enforced if the monitoring well is to be converted to a water producing well. Any abandoned wells shall be properly sealed as required by the Health Department.


J. Carter S. Gray, Manager
POLLUTION CONTROL

No authority is granted by this permit to construct, operate, or maintain any well in violation of any law, statute, code, ordinance, rule, or regulation of Memphis and Shelby County, Tennessee.
NON TRANSFERABLE POST OR FILE AT INSTALLATION ADDRESS.

GP 11/7/95