

N65928.AR.000905
NTC ORLANDO
5090.3a

LETTER REGARDING REGULATORY REVIEW AND NONCONCURRENCE REGARDING
CLOSURE ASSESSMENT FOR UNDERGROUND STORAGE TANK 2080 NTC ORLANDO FL
7/7/1999
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

July 7, 1999

Mr. Nick Ugolini
Code 1843 (UST RPM)
Southern Division
Naval Facilities Engineering Command
P.O. Box 190010
North Charleston, South Carolina 29419-9010

RE: Closure Assessment Report for Underground Storage Tank UST
2080 at Naval Training Center, Orlando, Florida

Dear Mr. Ugolini:

I have completed the review of Closure Assessment Report for UST 2080 at Naval Training Center, Orlando, dated June 1999 (received June 15, 1999), prepared and submitted by Tetra Tech NUS, Inc. I cannot concur with the consultant's recommendation for No Further Action as benzo(a)pyrene was detected in a soil sample at a concentration greater than its residential and industrial soil cleanup target level (SCTL). Site Assessment activities at this site should be conducted in accordance with Chapter 62-770, Florida Administrative Code, and a Site Assessment Report prepared and submitted.

If I can be of any further assistance with this matter, please contact me at (850) 488-3693.

Sincerely,

David P. Grabka
Remedial Project Manager

cc: Bill Bostwick, FDEP Central District Office
Rick Allen, Harding Lawson Associates, Jacksonville
Wayne Hansel, U.S. Navy, Southern Division
Nancy Rodriguez, USEPA, Region 4
Steve McCoy, Tetra Tech NUS, Oak Ridge, TN
Alan Aiken, CH2M Hill, Orlando

TJB

JNC
ESN

JJC JJC by ESN ESN