

N65928.AR.000908
NTC ORLANDO
5090.3a

LETTER REGARDING REGULATORY REVIEW AND CONCURRENCE ON CLOSURE
ASSESSMENT FOR UNDERGROUND STORAGE TANKS 113, 2018, 2510, AND 7171 NTC
ORLANDO FL
7/8/1999
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

July 8, 1999

Mr. Nick Ugolini
Code 1843 (UST RPM)
Southern Division
Naval Facilities Engineering Command
P.O. Box 190010
North Charleston, South Carolina 29419-9010

RE: Closure Assessment Report for Underground Storage Tanks USTs
113, 2018, 2510 and 7171 at Naval Training Center, Orlando,
Florida

Dear Mr. Ugolini:

I have completed the review of Closure Assessment Report for USTs 113, 2018, 2510 and 7171 at Naval Training Center, Orlando, dated June 1999 (received June 15, 1999), prepared and submitted by Tetra Tech NUS, Inc. I concur that no evidence of petroleum contamination was detected in soils at USTs 113, 2018 and 7171. However, Total Recoverable Petroleum Hydrocarbons (TRPHs) were detected at UST 2510 in soil sample 99CNS001-4 at a concentration greater than its residential Soil Cleanup Target Level (SCTL). It should be noted that although the Closure Assessments were not conducted strictly in accordance with DEP's Storage Tank Closure Assessment Requirements (Revised April 1998) in that a monitoring well was not installed at each site to determine if groundwater had been contaminated, the storage tanks being closed were not regulated under Chapter 62-761, Florida Administrative Code. Therefore, you are not required to conduct Site Assessment activities at USTs 113, 2018 and 7171, but are required to conduct Site Assessment activities at UST 2510 in accordance with Chapter 62-770, Florida Administrative Code, and a Site Assessment Report should be prepared and submitted for that site.

If I can be of any further assistance with this matter, please contact me at (850) 488-3693.

Sincerely,

David P. Grabka
Remedial Project Manager

Mr. Nick Ugolini
USTs 113, 2018, 2510 and 7171
Naval Training Center, Orlando
July 8, 1999
Page two

cc: Bill Bostwick, FDEP Central District Office
Rick Allen, Harding Lawson Associates, Jacksonville
Wayne Hansel, U.S. Navy, Southern Division
Nancy Rodriguez, USEPA, Region 4
Steve McCoy, Tetra Tech NUS, Oak Ridge, TN
Alan Aiken, CH2M Hill, Orlando

TJB JRC
ES JJC JJC by ESN ESN ESN