



DEPARTMENT OF THE NAVY
SOUTHERN DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
2155 EAGLE DR. P O BOX 190010
NORTH CHARLESTON, S C 29419 9010

32501.036
03.01.36.0016
N00204.AR.000565
NAS PENSACOLA
5090.3a

PLEASE ADDRESS REPLY TO THE
COMMANDING OFFICER, NOT TO
THE SIGNER OF THIS LETTER
REFER TO:

1993

5090
Code 1851

03 JUN 1993

CERTIFIED MAIL- RETURN RECEIPT REQUESTED

Ms. Allison Drew, RPM
U.S. EPA, Region IV
4WD/FFB
345 Courtland Street, N.E.
Atlanta, GA 30365

Dear Ms. Drew:

This letter is to formally inform your office, as per Section XI, Part D of the FFA, of the 20 May 1993 leak in the IWTP Sewer Line (PSC 36) located on NAS Pensacola. Enclosed is a copy of the NAVGRAM message reporting this Hazardous Release to the On-Site Commander in Pensacola. Since this site was one of the areas previously covered under the approved Immediate Removal Action Contingency Plan for P-100, Fuel Tankage, PWC personnel have completed line repairs.

If you should have any questions regarding the enclosure, please contact Ms. Linda A. Martin at (803) 743-0574.

Sincerely,

Linda A. Martin

LINDA A. MARTIN
RPM, NAS Pensacola
Installation Restoration, Section I

Encl :
(1) HS Release Report

copy to:
NAS Pensacola (Mr. Ron Joyner, Code 18520)
Ensafe (Mr. Henry Beiro) w/enc

UNCLASSIFIED

RTTUZYUW RHFJPOX0028 1412000-UUUU--RHFJSUU.

ZNR UUUUU

R 2120002 HAY 93 ZYB

FM PWC PENSACOLA FL//00//

TO NAS PENSACOLA FL//00500//

INFO CNET PENSACOLA FL

CNO WASHINGTON DC//OP-45//

COMNAVSEASYS COM WASHINGTON DC//00C//

NEESA PORT HUENEME CA//112//

COGARD NATIONAL RESPONSE CENTER WASHINGTON DC

COMNAVFACENGCOM ALEXANDRIA VA

SOUTHNAVFACENGCOM CHARLESTON SC//1851//

NAVAVNDEPOT PENSACOLA FL//0001//

DRMO PENSACOLA FL//005//

NSC PENSACOLA FL//00//

DDPP PENSACOLA FL//

BT

UNCLAS //N05090//

MSGID/GENADMIN/158860 PWC PENSACOLA//

SUBJ/HS RELEASE REPORT OPNAV 5090-3//

RMKS/1. 20 MAY 93 (DISCOVERED).

2. NPWC PENSACOLA, FL UIC 65114

3. RADFORD BLVD, BUILDING 782.

4. POWER PLANT (BOILERS)

5. PIPELINE

6. SULFURIC ACID AND SODIUM HYDROXIDE (CAUSTIC)

7. PH WADING FROM 8 TO 12

8. UNKNOWN

9. PIPELINE LEAK

10. NO VISIBLE EFFECT, ABSORBED INTO GROUND, ACID AND CAUSTIC

SELF-NEUTRALIZING

11. FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION: (ENFORCEMENT SECTION, RICK BRADBURN).

12. SOURCE OF ACID AND CAUSTIC SHUT OFF.

13. PWC IN HOUSE PERSONNEL WILL REPAIR LINE, SITE DESIGNATED AS

I.R. SITE 36, CONTAMINATED SOIL WILL BE RETURNED TO HOLE.

14. GARY SWEPENHISER, 911.1, 922-8587 OR (904) 452-8587

15. AN UNKNOWN QUANTITY OF ACID SOLUTION AND CAUSTIC SOLUTION WAS RELEASED FROM A 6 INCH FIBERGLASS FORCEMAIN COMING FROM BUILDING 782. APPROXIMATELY 3 TO 5 GALLONS PER MINUTE LEAKED FROM THE LINE WHEN THE PUMP STATION WAS IN OPERATION. IMMEDIATE ACTION WAS TO SECURE THE SOURCE OF THE HAZARDOUS SUBSTANCES. TESTS INDICATED A PH READING OF 8 TO 12 AT THE RELEASE SITE. THE 6 INCH FIBERGLASS FOR —IN IS PART OF THE INDUSTRIAL WASTE COLLECTION SYSTEM. THIS LINE IS DESIGNATED AS I.R. SITE 36. PWC PERSONNEL WITH OSHA TRAINING WILL MAKE THE LINE REPAIRS.//

BT

#0028

UNCLASSIFIED