

N00174.AR.001126
NSWC INDIAN HEAD
5090.3a

LETTER DISCUSSING PROPOSED DISCHARGE OF 51 55-GALLON DRUMS OF
WASTEWATER INTO SEWAGE PLANT NSWC INDIAN HEAD MD
1/24/1991
MARYLAND DEPARTMENT OF THE ENVIRONMENT



STATE OF MARYLAND
Department of the Environment

2500 BROENING HIGHWAY BALTIMORE, MARYLAND 21224



William Donald Schaefer
Governor

(301) 631- 3621

Robert Perciasepe
Secretary

January 24, 1991

Mr. Kenneth D. Morin, P.E., Director
Utilities/Environmental Division
Department of the Navy
Naval Ordnance Station
Indian Head, Maryland 20640-5000

Re: Naval Ordnance Station Wastewater Treatment Plant

Dear Mr. Morin:

This letter is provided in response to your request of January 7, 1991 regarding the proposed discharge of 51 55-gallon drums of wastewater which contain up to 6.0 ppb of PCB into the sewage plant regulated by State Discharge Permit No. 88-DP-2528. Based on the information provided by the Navy, the Maryland Department of the Environment has determined that the proposed discharge should not adversely impact the wastewater treatment plant. Therefore, the Department does not object to the discharge as described above. We suggest, however, that you contact the Solid Waste Division of the Hazardous and Solid Waste Administration at (301) 631-3364 for additional information on sludge disposal.

If you have any questions regarding this matter, please feel free to call John McGillen at (301) 631-3631.

Sincerely yours,

Karen G. Irons, P.E., Chief
Pretreatment and Enforcement Division

KGI:sas

ENCLOSURE(4)

